


PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. 04/26

Date : 04.04.2026

It is certified that an inspection team headed by MR. VIKAS KUMAR
TECHNICAL MANAGER (Name of Officers
with designation) from U.P. JAL NIGAM (RURAL) AMBEDKAR NAGAR (Name of
Department/Office) inspected the R.P.R.N. PUBLIC SCHOOL
RAMPUR SAKARWARI AKBARPUR AMBEDKAR NAGAR (Name & Address of
the School) on 02.04.2026 and found that the R.P.R.N. PUBLIC
SCHOOL RAMPUR SAKARWARI AKBARPUR (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of 03.04.2027.


Technical Manager

District Level Water Analysis Laboratory

Signature with Seal : UPJN Ambedkar Nagar

Name : VIKAS KUMAR

Designation : TECHNICAL MANAGER

To

R.P.R.N. PUBLIC SCHOOL
RAMPUR SAKARWARI AKBARPUR
AMBEDKAR NAGAR

(Name & Address of the Institution)



TEST REPORT
DISTRICT LEVEL WATER ANALYSIS LABORATORY OF
UTTAR PRADESH JAL NIGAM (RURAL), AMBEDKAR
NAGAR



ULR NO-TC172172600000089F

Report No- Chemical Test/0204202601/2026-2027 Date 04.04.2026 S.No-01 SAMPLE CODE A0204202601

Customer Details- R.P.R.N PUBLIC SCHOOL RAMPUR SAKARWARI AKBARPUR AMBEDKAR NAGAR

Office Name and Address Office of executive engineer ,khand karyalay, U.P. Jal Nigam(Rural),Sabun gali,Akbarpur,District-Ambedkar Nagar ,Pin-224122

Ref Letter No & Date R.P.R.N /175/2026

Basic details of sample

District	AMBEDKAR NAGAR	Block	AKBARPUR
Gram Panchayat	RAMPUR SAKARWARI	Village	RAMPUR SAKARWARI
Habitation	R.P.R.N PUBLIC SCHOOL RAMPUR SAKARWARI	Location	KHAS
Water Source	P.O.	Sample No.	1
Quantity of Sample	1 L	Date of S.C.	02.04.2026
Receiving Date	02.04.2026	S. Collector	SELF
Sample Depositor	ABHISHEK IVERMA	S.Method	IS 17614 (PART-05)-2021
Analysis Start Date	04.04.2026	Analysis Completion Date	04.04.2026

Environmental Condition

Temperature	25± 3 °C	Relative Humidity	50%±15%
-------------	----------	-------------------	---------

Technical Data of Analysis

S.No.	Analysed parameters	Unit of Measurement	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit in absence of alternate source	
1	2	3	4	5	6	7
1	Odour	NA	Agre	Agreeable	Agreeable	IS 3025(Part 05):2018
2	Taste	NA	Agre	Agreeable	Agreeable	IS 3025(Part 8):2023
3	Colour	HU	5.00	5	15	IS 3025(Part 04):2021
4	Ph	NA	7.20	6.50	8.50	IS 3025(Part 11):2022
5	Turbidity	NTU	1.34	1	5	IS 3025(Part 10):2023
6	TDS	mg/L	128.00	500	2000	IS 3025(Part 16):2023
7	Alkalinity	mg/L	100.00	200	600	IS 3025(Part 23):2023
8	Chloride	mg/L	10.00	250	1000	IS 3025(Part 32):2019
9	Hardness	mg/L	80.00	200	600	IS 3025(Part 21):2023
10	Calcium	mg/L	43.75	75	200	IS 3025(Part 40):2024
11	Magnesium	mg/L	14.11	30	100	APHA 24rd Edition -3500 Mg By Calculation Method
12	Sulphate	mg/L	16.78	200	400	IS 3025(Part 24):2022
13	Nitrate	mg/L	0.26	0	45	APHA 24rd EDITION -3500 NO3-B method
14	Fluoride	mg/L	0.04	1	1.5	IS 3025(Part 60):2023
15	Iron	mg/L	0.11	0	1	IS 3025(Part 53):2024

1. Statement of conformity

N/A

2. Reporting opinions and interpretations ISO 17025

N/A

Note:-

1. Source is not verified by the laboratory.
2. This Certificate refers only to the particular sample(s) submitted for testing.
3. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
4. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
5. Sample will be stored up to 7days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.

Lab Technician
Prepared By

End of Test Report

Authorized Signatory

VIKAS KUMAR
Technical Manager

Laboratory Contact details- Mob-9981490366

Email-eeupjn.cdambedkarnagar@gmail.com

District Level Water Analysis Laboratory
UPJN Ambedkar Nagar



TEST REPORT
DISTRCT LEVEL WATER ANALYSIS LABORATORY OF
UTTAR PRADESH JAL NIGAM (RURAL), AMBEDKAR
NAGAR

(Non NABL
Accredited
parameter)

Report No- Chemical Test/0204202601/2026-2027 Date 04.04.2026 S.No-01 SAMPLE CODE A0204202601

Customer Details- R.P.R.N PUBLIC SCHOOL RAMPUR SAKARWARI AKBARPUR AMBEDKAR NAGAR
 Office Name and Address Office of excutive engineer ,khand karyaalay, U.P. Jal Nigam(Rural),Sabun gali,Akbarpur,District-Ambekar Nagar ,Pin-224122

Ref Letter No & Date R.P.R.N./175/2026

Basic details of sample

District	AMBEDKAR NAGAR	Block	AKBARPUR
Gram Panchayat	RAMPUR SAKARWARI	Village	RAMPUR SAKARWARI
Habitation	R.P.R.N PUBLIC SCHOOL RAMPUR SAKARWARI	Location	KHAS
Water Source	R.O.	Sample No.	1
Quantity of Sample	1 L	Date of S.C.	02.04.2026
Receiving Date	02.04.2026	S. Collector	SELF
Sample Depositor	ABHISHEK VERMA	S.Method	IS 17614 (PART-05)-2021
Analysis Start Date	04.04.2026	Analysis Completion Date	04.04.2026

Environmental Condition

Temperature 25± 3 °C Relative Humidity 50%±15%

Technical Data of Analysis

S.No.	Analysed parameters	Unit of Measurement	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit in absence of alternate source	
1	2	3	4	5	6	7
16	Free Residual Chlorine	mg/L	0.00	0.2	1	IS 3025(Part-26):2004
17	E.coli	H2S Vials	0.00	0	0	H2S Vials
1.Statment of conformity						N/A
2.Reporting opinions and interpretations ISO 17025						N/A

Note:-
 1. Source is not varified by the laboratory.
 2. This Certificate refers only to the particular sample(s) submitted for testing.
 3. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
 4. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
 5. Sample will be stored up to 7days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.

Lab Technician
Prepared By

Authorized Signatory

Technical Manager

District Level Water Analysis Laboratory

UPJN Ambedkar Nagar

Signature
प्रबन्धक

आर०पी०आर०एन० पब्लिक स्कूल
रामपुर सकरवारी-अम्बेडकर नगर

End of Test Report

